



April 11, 2024

File: 21020-50/WW/OP/Arran

Village of Arran
Box 40
Arran, SK
S0A 0B0

Attention: Waterworks Owner

RE: Village of Arran - Rescinding Precautionary Drinking Water Advisory

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **"Precautionary Drinking Water Advisory" (PDWA)** issued by the Water Security Agency for the Village of Arran's potable water system for system users be rescinded as of Thursday, April 11, 2024.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The turbidity in the system is within regulatory requirements.
- Chlorine residuals throughout the distribution system are within regulatory requirements and
- Bacteriological sampling is within regulatory limits.
- Certified operator overseeing the water treatment plant

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Arran in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 621-2230.

Sincerely,

A handwritten signature in black ink, appearing to read "R Sheichuk".

Rick Sheichuk
Environment Officer
Water Security Agency
Ph. (306) 621-2230

cc. Compliance Promotion, Water Security Agency
Saskatchewan Health Authority – Yorkton Office